



## THE ROYAL BURGH OF ST ANDREWS COMMUNITY COUNCIL

21st June 2015

Attention: Ms. Fiona Kirk,  
Development Central  
Enterprise, Planning and Protective Services  
Fife Council  
Kingdom House  
Glenrothes KY7 5LY

Dear Ms. Kirk,

**15/01861/ADV - Display of 2 internally illuminated fascia signs and 1 non illuminated projecting sign**

**15/02018/LBC - Listed building consent for installation of 2 illuminated fascia signs and 1 non illuminated projecting sign  
151 Market Street St Andrews Fife KY16 9PF**

The Royal Burgh of St. Andrews Community Council (hereinafter “StACC”) is registering an OBJECTION to the above planning applications.

The size and internal illumination of the signage proposed for the Nationwide Building Society is contrary to the St Andrews Design Guidelines for Shop Fronts. Notably, the size of the letters proposed appear to be larger than the 300mm maximum detailed in Section 6.10 of the Design Guidelines, and the internal illumination of the signage is contrary to Design Guideline 71.

Therefore the StACC OBJECTS to the signage proposed for the Nationwide Building Society.

Please acknowledge safe receipt of this letter.

Yours sincerely,

Howard Greenwell  
Chair  
St. Andrews Community Council



cc: St. Andrews Community Council Planning Committee  
Cllr. Frances Melville  
Cllr. Dorothea Morrison  
Cllr. Keith McCartney  
Cllr. Brian Thomson